

## WATER DEARSENIFICATION UNIT

---

Description in brief	Arsenic content of the treated water through this unit comes down within WHO standards (< 10 ppb) from water having dissolved arsenic up to 500 ppb
Application/use of product	Useful for removal of arsenic to safe limit as set by WHO/BIS. The water filtration rate is 200 L/Hr (approx)
Salient features	Major portion of arsenic and iron precipitate/ co- precipitate in sedimentation chamber Oxidation of ferrous to ferric iron & As (III) to As (V). Double filtration of precipitates
Shelf life	10 years from the date of manufacture



**WATER DEARSENIFICATION UNIT**